

## ADDENDUM NO. 1

### Scope B Concrete Slurry and Steel Floor Installation Station H, 25 Hill Tank No. 2 Rehabilitation, Job #26-3200

Date Issued: September 4, 2025  
Issued By: West Kern Water District

#### REVISION TO BID PROPOSAL:

Item B-4 is revised to:

Item No.	Quantity	Units	Description of Bid Item	Unit Bid Price	Total Item Price
B-4	1	LS	Furnish and install new 115' diameter, 5/16-inch thick, non-copper bearing, A36 steel floor bottom, shop primed		

#### CLARIFICATIONS:

##### 1. Safety Notice

The tank roof structure has exposed wooden beams. While they are secured, falling debris is possible during wind/weather events. Contractor must take appropriate precautions to protect workers and the work area.

##### 2. Site Security

The site is fenced, but the Contractor is responsible for securing any stored equipment or materials. The District is not liable for losses or damage.

##### 3. Restroom Facilities

Contractor must provide and maintain portable restrooms for on-site personnel.

ACKNOWLEDGE THIS ADDENDUM ON BID FORM.

Please sign and return or fax to:

West Kern Water District  
P.O. Box 1105  
Taft, CA 93268

Phone 661 763-3151  
Fax 661 765-4271

Company: \_\_\_\_\_

Signature: \_\_\_\_\_

Title: \_\_\_\_\_

Date: \_\_\_\_\_